



N° Schéma unif. - N° Diagram	376606	
Courant J de B - Busbar current	In	400 A
Tension de service - Service voltage	U	20 KV
Tension de choc - Impulse voltage	Uw	125 KVc
Crt. courte durée - Short time current	Ith	1 s 12.5 kA
N° Cde - N° Contrl	C.42735	001 A



<b>GEC ALSTHOM</b>		71010 Maçon France	
FLUOKIT H.24		MASSE	210 kg
DESIGNATION	DOUBLE DERIVATION		
TYPE	DD.AC	REFERENCE	809939/004
NORME Stand.	HN64S41	TENSION - VOLTAGE	U 24 KV
IP	305	COURANT - CURRENT	In 400 A
TENUE aux CHOCs - IMPULSE VOLTAGE	Uw	125	KVc
COURANT COURTE DUREE - SHORT TIME CURRENT	Ith	1 s	12.5 kA
POUVOIR de COUPURE - BREAKING CURRENT	Isc	400	A
POUVOIR de FERMETURE - MAKING CURRENT	Ima	31.5	kA
C N° SERIE		244030	
E SERIAL N°		244030	
DATE		46/90	

<b>ALSTOM</b>		71010 Maçon France	
FLUOKIT M24 - V 93		MASSE	210 kg
DESIGNATION	TRANSFORMATEURS DE MESURE		
TYPE	TM	REFERENCE	873 930 / A4 - B4
NORME	C 13100	TENSION ASSIGNEE RATED VOLTAGE	U 24 KV
IP	2XC	COURANT ASSIGNE RATED CURRENT	In 50 A
TENSION DE CHOC - IMPULSE VOLTAGE	Uw	125	KVc
COURANT COURTE DUREE - SHORT TIME CURRENT	Ith	1 s	12.5 kA
POUVOIR de COUPURE - BREAKING CAPACITY	Isc		A
POUVOIR de FERMETURE - MAKING CAPACITY	Ima		kA
N° COMMANDE ORDER N°7			
C N° SERIE		1211499	
E SERIAL N°		1211499	
DATE		39/98	

<b>GEC ALSTHOM</b>		71010 Maçon France	
FLUOKIT H.24		MASSE	120 kg
DESIGNATION	INTERRUPTEUR COORDONNES		
TYPE	PFA	REFERENCE	809940/005
NORME Stand.	HN64S41	TENSION - VOLTAGE	U 24 KV
IP	305	COURANT - CURRENT	In 50 A
TENUE aux CHOCs - IMPULSE VOLTAGE	Uw	125	KVc
COURANT COURTE DUREE - SHORT TIME CURRENT	Ith	1 s	12.5 kA
POUVOIR de COUPURE - BREAKING CURRENT	Isc	SVT FUSIBLES	A
POUVOIR de FERMETURE - MAKING CURRENT	Ima	31.5	kA
C N° SERIE		248337	
E SERIAL N°		248337	
DATE		05/91	

<b>GEC ALSTHOM</b>		71010 Maçon France	
FLUOKIT H.24		MASSE	210 kg
DESIGNATION	DOUBLE DERIVATION		
TYPE	DD.AC	REFERENCE	809939/004
NORME Stand.	HN64S41	TENSION - VOLTAGE	U 24 KV
IP	305	COURANT - CURRENT	In 400 A
TENUE aux CHOCs - IMPULSE VOLTAGE	Uw	125	KVc
COURANT COURTE DUREE - SHORT TIME CURRENT	Ith	1 s	12.5 kA
POUVOIR de COUPURE - BREAKING CURRENT	Isc	400	A
POUVOIR de FERMETURE - MAKING CURRENT	Ima	31.5	kA
C N° SERIE		244029	
E SERIAL N°		244029	
DATE		46/90	

<b>ALSTOM</b>		71010 Maçon France	
FLUOKIT M24 - V 93		MASSE	460 kg
DESIGNATION	PROTECTION GENERALE BARRES		
TYPE	PGB	REFERENCE	873 925 / A4 - B4
NORME	C 13100	TENSION ASSIGNEE RATED VOLTAGE	U 24 KV
IP	2XC	COURANT ASSIGNE RATED CURRENT	In 400 A
TENSION DE CHOC - IMPULSE VOLTAGE	Uw	125	KVc
COURANT COURTE DUREE - SHORT TIME CURRENT	Ith	1 s	12.5 kA
POUVOIR de COUPURE - BREAKING CAPACITY	Isc	12.5	A
POUVOIR de FERMETURE - MAKING CAPACITY	Ima	31.5	kA
N° COMMANDE ORDER N°		C42735 002	
C N° SERIE		1211500	
E SERIAL N°		1211500	
DATE		39/98	